



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)  
**All India Institute of Medical Sciences, Raipur (Chhattisgarh)** Tatibandh, GE Road,  
 Raipur-492099 (CG)  
 www.aiimsraipur.edu.in  
 Ph.No.0771-2572930, e-mail: ee.civil@aiimsraipur.edu.in

अधिसूचना संख्या: 8304


Letter No.54(8015)/EE/AIIMS/RPR/ 8304

Dt. 03/09/2018

**CORRIGENDUM**

Name of work- "Replacement of existing 2x18 watt 4pin CFL down lighter by 15watt LED down lighter at Medical college Building  
 AIIMS Campus, Raipur".  
 Tender N.I.T. NO. 01/EE/AIIMS/2018-19 Dt:24.08.2018

Sl. No.	Page No/ Clause No/ Point No	Sl. No.	Parameters	AIIMS Raipur Requirement	OEM Test to be carried out/document to be submitted	Bidders Confirmation
1	As mentioned in tender document Page no. 90, Sr.No.11.	Existing sentence 11	Reported L70 (Lumen maintenance)	≥ 30000 hrs. .	LM-80 test report from NABL Acc. Lab	_____ hrs. ref at page# _____ of submission
	To be read as	11	LED Life with L70 Criteria (Lumen maintenance)	≥ 50000 hrs. .	LM-80 test report from NABL Acc. Lab/ By OEM	_____ hrs. ref at page# _____ of submission

  
 इंजी. मनोज रस्तोगी  
 Er. Manoj Rastogi  
 कार्यपालन अभियंता (सिविल)  
 Executive Engineer (Civil)  
 एम्स, रायपुर (छ.ग.)  
 AIIMS Raipur (CG)

		<b>Existing sentence</b>				
2	As mentioned in tender document Page no. 91, Sr.No.20.	20	System/LED efficacy	$\geq 110$ lm/w (min.)	To confirm	lm/W of ref. page# _____ of submission
	<b>To be read as</b>					
	20 A		System Efficacy	$\geq 110$ lm/w (min.)	To confirm	lm/W of ref. page# _____ of submission
	20 B		LED Efficacy	$\geq 120$ lm/w (min.)	To confirm	lm/W of ref. page# _____ of submission

*Manoj Rastogi*  
21/01/2018

Er. Manoj Rastogi  
Executive Engineer (Civil)  
AIIMS, Raipur

Copy to:-

1. O/o Director, AIIMS, Raipur. : For kind information please.
2. Dy. Director (Administration), AIIMS Raipur : For necessary action please.
3. IT, AIIMS Raipur : For publishing at AIIMS Raipur website.