



Corrigendum

Name of Work:- Replacement of existing light fixture with LED light fixture at Operation theatre Trauma Hospital Building & B block Radio diagnosis department, AIIMS Campus, Raipur.

Reference: NIT -25/EE/AIIMS/2018-19, Date:-01/11/2018.

Changes to be considered in the above referred Notice Inviting Tender

Existing	To be read as
1) Page 33, heading; Technical specification for 4100 lumen (min),39W (Max) LED street light fixture.	1) Page 33, heading; Technical specification for 4100 lumen (min),39W (Max) LED Channel type fixture suitable for suspended/surface mounted
2) Page 33, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED street light fixture, lumen output-4100 lumen (min), total watt (including driver) 39 W(max), fixture luminous efficacy-170 lumen/watt (min),suitable for surface mounting, rest as per specification mentioned below.	2) Page 33, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED Channel type fixture, lumen output-4100 lumen (min), total watt (including driver) 39 W(max), fixture luminous efficacy-105 lumen/watt (min),suitable for surface mounting, rest as per specification mentioned below.
3) Page 33, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;- AC 160-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv.	3) Page 33, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;- AC 150-270 Volt universal electronic driver with inbuilt surge protection of minimum 2kv.
4) Page 34, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;- 5500+/-300k	4) Page 34, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;- 5700+/-300k
5) Page 35, ANNEXURE-1,point no 20,AIIMS Raipur Requirement;- 170 lm/w (min)	5) Page 35, ANNEXURE-1,point no 20,AIIMS Raipur Requirement;- 105 lm/w (min)
6) Page 36, heading; Technical specification for 3745 lumen (min),42W (Max) LED street light fixture.	6) Page 36, heading; Technical specification for 3745 lumen (min),42W (Max) LED cleanroom fixture.
7) Page 36, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED street light fixture, lumen output-3745 lumen (min), total watt (including driver) 42 W(max), fixture	7) Page 36, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED Cleanroom fixture, lumen output-3745 lumen (min), total watt (including driver) 42 W(max),

luminous efficacy-150 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below. high power bright white LED's with wattage shall be greater than 1W and less than 3W

- 8) Page 36, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 4100 lumen (min.)
- 9) Page 36, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;- AC 160-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv.
- 10) Page 37, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;- 5500+/-300k
- 11) Page 38, ANNEXURE-1,point no 20,AIIMS Raipur Requirement;- 150 lm/w (min)
- 12) Page 39, heading; **Technical specification for 1527 lumen (min),18.9*W (Max) LED street light fixture.**
- 13) Page 39, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED street light fixture, lumen output-1527 lumen (min), total watt (including driver) 18.9 W(max), fixture luminous efficacy-120 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below. High power bright white LED's with wattage shall be greater than 1w and less than 3w.
- 14) Page 39, ANNEXURE-1,point no 2,AIIMS Raipur Requirement;-18.9 W max including driver (+5% tolerance shall be allowed)
- 15) Page 39, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;-152 lumen (min.)
- 16) Page 39, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 160-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv
- 17) Page 40, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;-5500+/-300k

fixture luminous efficacy-89 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below. high power bright white LED's with wattage shall be greater than 1W and less than 3W

- 8) Page 36, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 3745 lumen (min.)
- 9) Page 33, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;- AC 150-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv.
- 10) Page 37, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;- 5700+/-300k
- 11) Page 38, ANNEXURE-1,point no 20,AIIMS Raipur Requirement;- 130 lm/w (min)
- 12) Page 39, heading; **Technical specification for 1500 lumen (min),18 W (Max) LED surface fixture.**
- 13) Page 39, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED light fixture, lumen output-1500 lumen (min), total watt (including driver) 18 W(max), fixture luminous efficacy-83 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below. High power bright white LED's with wattage shall be greater than 1w and less than 3w.
- 14) Page 39, ANNEXURE-1,point no 2,AIIMS Raipur Requirement;-18 W max including driver (+5% tolerance shall be allowed)
- 15) Page 39, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;-1500 lumen (min.)
- 16) Page 39, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 150-270 Volt universal electronic driver with inbuilt surge protection of minimum 2kv
- 17) Page 40, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;-6000+/-300k

- | | |
|--|--|
| <p>18) Page 40, ANNEXURE-1, point no 13, AIIMS Raipur Requirement; -Ra 70(min.)</p> <p>19) Page 41, ANNEXURE-1, point no 18, AIIMS Raipur Requirement; - 160-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>20) Page 41, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; - 120 lm/w (min.)</p> <p>21) Page 42, heading; Technical specification for 903 lumen (min), 10 W (Max) LED street light fixture.</p> <p>22) Page 42, ANNEXURE-1, point no 1, AIIMS Raipur Requirement; -LED street light fixture, lumen output-903 lumen (min), total watt (including driver) 10 W(max), fixture luminous efficacy-120 lumen/watt (min), suitable for surface mounting, rest as per specification mentioned below.</p> <p>23) Page 43, ANNEXURE-1, point no 5, AIIMS Raipur Requirement; -AC 160-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv</p> <p>24) Page 43, ANNEXURE-1, point no 10, AIIMS Raipur Requirement; -5500+/-300k</p> <p>25) Page 44, ANNEXURE-1, point no 18, AIIMS Raipur Requirement; - 160-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>26) Page 44, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; - 120 lm/w (min.)</p> <p>27) Page 45, heading; Technical specification for 1800 lumen (min), 18 W (Max) LED street light fixture.</p> <p>28) Page 45, ANNEXURE-1, point no 1, AIIMS</p> | <p>18) Page 40, ANNEXURE-1, point no 13, AIIMS Raipur Requirement; -Ra 80(min.)</p> <p>19) Page 41, ANNEXURE-1, point no 18, AIIMS Raipur Requirement; - 150-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>20) Page 41, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; - 83 lm/w (min.)</p> <p>21) Page 42, heading; Technical specification for 903 lumen (min), 10 W (Max) LED batten fixture.</p> <p>22) Page 42, ANNEXURE-1, point no 1, AIIMS Raipur Requirement; -LED batten light fixture, lumen output-903 lumen (min), total watt (including driver) 10 W(max), fixture luminous efficacy-90 lumen/watt (min), suitable for surface mounting, rest as per specification mentioned below.</p> <p>23) Page 43, ANNEXURE-1, point no 5, AIIMS Raipur Requirement; -AC 150-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv</p> <p>24) Page 43, ANNEXURE-1, point no 10, AIIMS Raipur Requirement; -6500+/-300k</p> <p>25) Page 44, ANNEXURE-1, point no 18, AIIMS Raipur Requirement; - 150-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>26) Page 44, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; - 90 lm/w (min.)</p> <p>27) Page 45, heading; Technical specification for 1800 lumen (min), 18 W (Max) LED light fixture.</p> <p>28) Page 45, ANNEXURE-1, point no 1, AIIMS</p> |
|--|--|

<p>Raipur Requirement;-LED street light fixture, lumen output-1800 lumen (min), total watt (including driver) 18 W(max), fixture luminous efficacy-120 lumen/watt (min),suitable for surface mounting, rest as per specification mentioned below.</p> <p>29) Page 46, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 903 lumen (min.)</p> <p>30) Page 46, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 160-265 Volt universal electronic driver with inbuilt surge protection of minimum 2kv</p> <p>31) Page 46, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;-5500+/-300k</p> <p>32) Page 46, ANNEXURE-1,point no 14,AIIMS Raipur Requirement;- <10%</p> <p>33) Page 47, ANNEXURE-1,point no 18,AIIMS Raipur Requirement;- 160-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>34) Page 49, heading; Technical specification for 1500 lumen (min),15 W (Max) LED street light fixture.</p> <p>35) Page 49, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED street light fixture, lumen output-1500 lumen (min), total watt (including driver) 15 W(max), fixture luminous efficacy-130 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below</p> <p>36) Page 49, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 903 lumen (min.)</p> <p>37) Page 49, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 160-265 Volt universal electronic driver with inbuilt surge</p>	<p>Raipur Requirement;-LED batten fixture, lumen output-1800 lumen (min), total watt (including driver) 18 W(max), fixture luminous efficacy-120 lumen/watt (min).</p> <p>29) Page 46, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 1800 lumen (min.)</p> <p>30) Page 46, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 150-270 Volt universal electronic driver with inbuilt surge protection of minimum 2kv</p> <p>31) Page 46, ANNEXURE-1,point no 10,AIIMS Raipur Requirement;-6500+/-300k</p> <p>32) Page 46, ANNEXURE-1,point no 14,AIIMS Raipur Requirement;- <20%</p> <p>33) Page 47, ANNEXURE-1,point no 18,AIIMS Raipur Requirement;- 150-270 Volt universal electronic drivers with protection of minimum 2.0 kv internal surge plus under voltage, over voltage, short circuit, open circuit, no load EMI, environmental</p> <p>34) Page 49, heading; Technical specification for 1500 lumen (min),15 W (Max) LED Down light fixture Dia-158mm, Height 40mm.</p> <p>35) Page 49, ANNEXURE-1,point no 1,AIIMS Raipur Requirement;-LED Down light fixture, lumen output-1500 lumen (min), total watt (including driver) 15 W(max), fixture luminous efficacy-100 lumen/watt (min),suitable for recess mounting, rest as per specification mentioned below</p> <p>36) Page 49, ANNEXURE-1,point no 3,AIIMS Raipur Requirement;- 1500 lumen (min.)</p> <p>37) Page 49, ANNEXURE-1,point no 5,AIIMS Raipur Requirement;-AC 90-265 Volt universal electronic driver with inbuilt</p>
--	---

<p>protection of minimum 2kv</p> <p>38) Page 50, ANNEXURE-1, point no 10, AIIMS Raipur Requirement; -5500+/-300k</p> <p>39) Page 51, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; -130 lm/w (min.)</p>	<p>surge protection of minimum 2kv</p> <p>38) Page 50, ANNEXURE-1, point no 10, AIIMS Raipur Requirement; -6500+/-300k</p> <p>39) Page 51, ANNEXURE-1, point no 20, AIIMS Raipur Requirement; -120 lm/w (min.)</p>
<p>All other terms and conditions will remain same</p>	

The Tender forms and other details can be seen/downloaded from the website www.aiimsraipur.edu.in

O/c

Manoj
16/11/2018

Er. Manoj Rastogi
Executive Engineer (Civil)
AIIMS Raipur, Chhattisgarh

Copy to:

1. The Deputy Director (Admin), AIIMS Raipur -for information please.
2. IT Department, AIIMS Raipur -for necessary action please.

Manoj
6/11/2018

Er. Manoj Rastogi
Executive Engineer (Civil)
AIIMS Raipur, Chhattisgarh