



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)
All India Institute of Medical Sciences, Raipur (Chhattisgarh)
 Tatibandh, GE Road,
 Raipur-492 099 (CG)

Phone No. 0771-2572930, e-mail: se@aiimsraipur.edu.in

No. 54 (8015) SE/AIIMS/RPR/2017-18/ **6731**

Date:-21/03/2018

Corrigendum

Name of Work: - Replacement of existing 250 W MH lamp street light fitting by 90 W LED Fittings at AIIMS Raipur.


Reference:-NIQ-23/SE/AIIMS/RPR/2017-18/6647, Date:-10/03/2018.

Changes to be considered in the above referred following points in terms & Conditions in Notice Inviting Quotation. :-

1. Mounting Height of fixture is 9 Mtr. With pole span 24 Mtr. With road width 12 Mtr. Arm length 1.5 Mtr., requirement of average lux with uniformity of 0.67.
2. Bidders should submit design dia-lux report to conform the lux level on road; minimum lux should be 15 lux.
3. Bidder should submit two bid, Technical bid & financial bid, after opening of technical bid the eligible bidder has to provide 3 nos. sample the quoted item for mock-up purpose within 3 days.

All other terms and conditions will remain same.

The Quotation forms and other details can be seen /downloaded from the website www.aiimsraipur.edu.in.


 Superintending Engineer
 AIIMS, Raipur

Copy to:-

1. The Director, AIIMS Raipur
 2. The Deputy Director (Admin), AIIMS Raipur
 3. Finance Advisor, AIIMS Raipur
 4. IT Department, AIIMS Raipur
- } - for information pleases.
 - for Necessary action please


 Superintending Engineer
 AIIMS, Raipur