

No. NIQ/09/SE/AIIMS/RPR/2018-19.

Date: 26/05/2018

NOTICE INVITING QUOTATION

Sealed Item Rates quotations for the below mentioned work are hereby invited by The Superintending Engineer on behalf of The Director, AIIMS Raipur from approved and eligible Contractors/Firms/Individuals/Supplier having GST/TIN/PAN no./relevant documents along with Earnest Money in the form of Demand Draft or Pay Order or Banker's Cheque or Deposit at Call Receipt or Fixed Deposit Receipt of a Scheduled Bank (drawn/ Pledged in favour of AIIMS, Raipur) and should be submitted to office of Project Cell, Hospital Administrative Block, Gate No-1, AIIMS Raipur up to 3:00 pm on 04th June 2018. The Bidder must address the NIQ inviting authority and mention The NIQ no, Name of Work, Name of Agency over the sealed envelope. The schedule of quantity must be filled with **blue ball point pen only** and shall be duly sealed and signed by the Proprietor/Contractor/ Authorised Signatory of the Firm, correction may be avoided. The bidder must self-certify all the documents in the envelope. The right to reject any or all the quotations without assigning any reasons and accept full or part of Quotation thereof shall rest with the Engineer- In-Charge. The quotations shall be opened on the same day at 3:30 pm. As per detailed below:-

Sl No	NAME OF WORK	E.M.D in ₹	TIME
1	Cleaning of PVC & RCC overhead & underground water Tanks at AIIMS Raipur.	2,350/-	02 (Two) Months


SCHEDULE OF QUANTITY

Sl.	Description of items	Unit	Qty	Rate	Amount
.....As PER SHEET ATTACHED.....					

Conditions:

1. Rate should be quoted inclusive of all the taxes (Nothing to be paid extra on this account).
2. F.O.R. Project Cell, Hospital Administrative Block, Gate No-01, AIIMS Raipur.
3. All the relevant documents to be submitted must be signed and sealed by the Proprietor/Contractor/ Authorised Signatory of the Firm.
4. Work should be completed within 02 (Two) Months from the date of issue of WO.
5. Work has to be done as per CPWD specification & direction of Engineer In-charge.
6. As the work is to be done in running Hospital, the restrictions if any has to be obeyed by the Contractor.
7. Damage if any done/happened by the contractor then, he has to make it good as original.
8. If the Agency fails to clean the tanks as per the tank cleaning schedule given by AIIMS, A penalty of ₹ 500/- may be imposed on the Agency for delay of each tank.
9. Payment shall be done for the work done as measured.
10. Labour law to be obeyed by the agency.
11. All the arrangements i.e. Water Supply, Electricity Supply, All Material, Machinery, Labour and auxillary supplies required by the manpower for the work to be arranged by the agency and nothing will be arranged by AIIMS or nothing extra to be paid in this regard.


Junior Engineer (Civil)
AIIMS Raipur


Superintending Engineer
AIIMS Raipur

Schedule of Quantity

AIIMS Raipur


Name of Work: Cleaning of PVC & RCC overhead & underground water Tanks at AIIMS Raipur

S no	Description of item	Qty	Unit	Rate		Amount
				In Figures	In Words	
1	Cleaning of terrace/loft water storage tank (inside surface area) upto 5000 litre capacity at all heights with coconut brushes, duster etc., removal of silt, rubbish from the tank and cleaning the tank with fresh water disinfecting with bleaching powder @ 0.5gm per litre capacity of tank, including marking the date of cleaning on the side of tank body with the help of stencil and paint and disposing of malba, all complete as per direction of Engineer-in-Charge. (The old date already written on tank should be removed with paint remover or black paint and if date is not written with the stencil or old date is not removed deduction will be made @ Rs. 0.10 per litre if during cleaning any GI fittings or ball cock is damaged that is to be repaired by contractor at his own cost and nothing extra will be paid on this account)	62500	litre			
2	Cleaning of under ground sump/ water tank, Over Head R.C.C. Tank (independent staging) including disposal of slit and rubbish, all as per direction of Engineer-in-Charge. The cleaning shall consist following operations:- (i) Tank shall be emptied of water by pumping & bottom shall be cleaned of slit and other deposits. (ii) Entire surface area of the sump shall then scrubbed thoroughly with wire brush etc. and pressure washed with water. (iii) Chlorination of RCC internal surface by liquid chlorine. (iv) The treated surface shall be dried using air jetting and all loose particles shall be removal from the surface. (v) Finally the surface shall be treated with ultraviolet radiation etc. as per direction of Engineer-in-Charge.	4172.0	Sqm			
Total						

Total in words.....

Total in Figure.....

(Signature of Contractor)


 Superintending Engineer
 Project Cell, AIIMS Raipur