



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)
All India Institute of Medical Sciences, Raipur (Chhattisgarh)
Tatibandh, GE Road,
Raipur-492 099 (CG)

Phone No. 0771-2572930, e-mail: ee.civil@aiimsraipur.edu.in

NIQ No: 36/EE/AIIMS/RPR/2019-20

Date: 10/01/2020

NOTICE INVITING QUOTATION

Sealed quotation is hereby invited by The Executive Engineer (Civil) on behalf of The Director, AIIMS Raipur from the interested **contractor/ supplier having GST No.** should be submitted to office of Project Cell, Hospital Administrative Block, Gate No-1, AIIMS Raipur up to **12:00 Noon** on **17th January 2020**. The right to reject any or all the quotations without assigning any reasons thereof shall rest with undersigned. The quotations will be opened on the same day at **12:30 PM**. As per detailed below:-

SI No	NAME OF WORK	EST. COST in Rs.	TIME
1	Supply of 32 watt 2ft x 2ft LED recess mounting light fixture for Hospital Building, AIIMS Campus, Raipur.	Rs.2,49,314.00	15 days

SCHEDULE OF QUANTITY

SI No	Description of items	Unit	Quantity	Rate	Amount
1AS PER ATTACHED SHEET.....				

Term & Conditions:

1. Item rates should be quoted inclusive of all taxes (Nothing to be paid extra on this account).
2. Supply of materials as per Schedule of Quantity should be delivered within 15 Days from the date of issue of Supply order.
3. Quotation No/Name and Due date of opening must be written on top of envelop.
4. The **first and final bill** payment will be done after supply of all items as per specification and satisfaction of Engineer-In-Charge.
5. **LD @ 0.5% of delayed supply per week or part of week for delay of supply of material subject to maximum up to 10%.**
6. **Approved make:- Wipro/Bajaj/Crompton/Havells/Philips/Osram**
7. **Condition:-**
 - a) Authorization certificate from source Manufacturer should be attached.
 - b) Certificate LM79 report from NABL approved lab (certificate should be attached), LM80 report from the source Manufacturer (certificate should be attached) , TM21 certificate & Driver manufacturing type test driver certificate should be attached.
 - c) Technical datasheet for the above product should be attached.

- d) **SD@2.5% will be deducted from Final Bill & will release after 6 month of successful completion.**
8. Rates quoted by the contractor in figures and words shall be accurately filled in so that there is no discrepancy in the rates written in figures and words. If the rate mismatch in figure and word, then the rate quoted in figure will be considered only. If any item the quoted rate remains blank, then it is assumed that the agency will provide that item without any cost.



[Signature]
10/11/2020

Executive Engineer (C)
AIIMS Raipur (Chhattisgarh)

SCHEDULE OF QUANTITY					
Name of Work: Supply of 32 watt 2fx2ft LED recess mounting light fixture for Hospital Building, AIIMS Campus, Raipur.					
S.No.	ITEM DESCRIPTION	UNIT	QTY	Rate	
				In Figure	In Words
(a)	supply of 32 watt LED recess mounted 600x600mm light fitting , system lumen output minimum 3500 lumens full glow, die cast aluminium housing, CCT 6500+-300K, CRI>=80, electronic driver having PF>=0.9, THD<20% & minimum of 3KV surge/burst protection, burning hours not less than 50,000 hrs.	Each	86		
Total amount					
Name of Agency:					
Full Address					
Contact No					
Valid email id:					
AIIMS Raipur					

