



अखिल भारतीय आयुर्विज्ञान संस्थान, रायपुर (छत्तीसगढ़)
All India Institute of Medical Sciences, Raipur (Chhattisgarh)

Tatibandh, GE Road,
Raipur-492 099 (CG)

Phone No. 0771-2572930, e-mail: ee.civil@aiimsraipur.edu.in

NIQ No: 45/EE/AIIMS/RPR/2019-20

Date: 23/01/2020

NOTICE INVITING QUOTATION

Sealed quotation is hereby invited by The Executive Engineer (Civil) on behalf of The Director, AIIMS Raipur from the interested **contractor/ supplier having GST No.** should be submitted to office of Project Cell, Hospital Administrative Block, Gate No-1, AIIMS Raipur up to **12:00 Noon** on **27th January 2020**. The right to reject any or all the quotations without assigning any reasons thereof shall rest with undersigned. The quotations will be opened on the same day at **12:30 PM**. As per detailed below:-

Sl No	NAME OF WORK	EST. COST in Rs.	TIME
1	Supply of 3KVA Single phase online UPS.	Rs.2,21,600.00	15 days

SCHEDULE OF QUANTITY

Sl No	Description of items	Unit	Quantity	Rate	Amount
1AS PER ATTACHED SHEET.....				

Term & Conditions:

1. Percentage rates should be quoted inclusive of all taxes (Nothing to be paid extra on this account).
2. Supply of materials as per Schedule of Quantity should be delivered within 15 Days from the date of issue of Supply order.
3. Quotation No/Name and Due date of opening must be written on top of envelop.
4. The **first and final bill** payment will be done after supply of all items as per specification and satisfaction of Engineer-In-Charge.
5. **LD @ 0.5% of delayed supply per week or part of week for delay of supply of material subject to maximum up to 10%.**
6. **Technical Specification for 3 KVA UPS as per mentioned below;**

"Annexure-A"

- Input Voltage: 230V AC
- Input Voltage Range: 120 - 280 V or better
- THDi: < 10%
- Input Frequency Range: 40 - 60 Hz or better
- Operating Temperature: 0 - 40 ° C or better
- Output PF: ≥ 0.8
- Output Frequency: 50 / 60 Hz
- Output Waveform Type: Sine wave
- Overload Capacity 110%: 10 mins
- Overload Capacity 125%: 1 min
- Output Voltage (in VAC): 200 V / 220 V / 230 V / 240 V
- Overall Efficiency: > 85%
- With ECO Mode

Protection: Ingress Protection: IP 20, Input Low / High Protection, Output Low / High Protection, Short Circuit Protection, Surge Protection

Battery type: valve-regulated lead–acid battery (VRLA battery)

UPS Stand and Battery Rack: Best Suitable for Battery open housing and stand for UPS.

Certificates: UE / CE Certificate, RoHS

Compliance: IEC 620 40 -1, IEC 620 40 - 2, IS 16242: Part 1

7. **Security Deposit @2.5% of quoted value will be deducted & will be released after 06(Six) months of successfully completion of work.**
8. The bidder shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work.
9. Bidders are suggested to visit the site with Junior Engineer (E), Er. Shashank Jain before participating in the quotation.
10. **Method of application:**
 - a) If the bidder is an individual, the application shall be signed by him above his full type written name and current address.
 - b) If the bidder is a proprietary firm, the application shall be signed by the proprietor above his full type written name and the full name of his firm with its current address.
 - c) If the bidder is a firm in partnership, the application shall be signed by all the partners of the firm above their full type written names and current addresses, or, alternatively, by a partner holding power of attorney for the firm. In the later case a certified copy of the power of attorney should accompany the application. In both cases a certified copy of the partnership deed and current address of all the partners of the firm should accompany the application.
 - d) If the bidder is a limited company or a corporation, the application shall be signed by a duly authorized person holding power of attorney for signing the application accompanied by a copy of the power of attorney. The bidder should also furnish a copy of the Memorandum of Articles of Association duly attested by a Public Notary.



Executive Engineer (C)
AIIMS Raipur (Chhattisgarh)

Schedule of Quantity

Name of Work: Supply of 3KVA Single phase online UPS.

S.No.	ITEM DESCRIPTION	UNIT	QTY	RATE	AMOUNT	APPROVED MAKE
1	3 KVA Single phase online UPS provided with (1) In-built Isolation transformer (2) 6 nos. 12V, 28AH VRLA batteries (3) Battery and UPS stand as required (4) 2 year CAMC Technical specification and make list attached in Annexure-“A”	Nos.	4	55,400.00	221,600.00	UPS: Emerson / APC/ Numeric/ Vertiv/ Legrand Battery: Exide/ Amara Raja/ HBL/ Luminous
	Total Amount				221,600.00	
Percentage Rate Quoted by the Agency	In Figure					
	In Words					
Name of Agency:						
Address Details:						
Contact no:						
Valid email id:						



आरोग्यम् सुखं सम्पदा