



Bid Number/बोली क्रमांक (बिड संख्या):

GEM/2024/B/4837309

Dated/दिनांक : 15-04-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	29-04-2024 14:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	29-04-2024 14:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Health And Family Welfare
Department Name/विभाग का नाम	Department Of Health And Family Welfare
Organisation Name/संगठन का नाम	All India Institute Of Medical Sciences (aiims)
Office Name/कार्यालय का नाम	Raipur
Total Quantity/कुल मात्रा	1632
Item Category/मद केटेगरी	Stationary Value Regulated Lead Acid Batteries as per IS 15549 (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	150 Lakh (s)
OEM Average Turnover (Last 3 Years)/मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)	450 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

Bid Details/बिड विवरण	
Past Performance/विगत प्रदर्शन	50 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	H1-Highest Priced Bid Elimination
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Stationary Value Regulated Lead Acid Batteries as per IS 15549
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	Bank of India
EMD Amount/ईएमडी राशि	400000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	42

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

AIIMS Raipur
Raipur, Chhattisgarh
(Aims Raipur)

Splitting/विभाजन

Bid splitting not applied./बोली विभाजन लागू नहीं किया गया

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
4. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.
6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:
 - i. If number of technically qualified bidders are only 2 or 3.
 - ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
 - iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
 - iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
 - v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Stationary Value Regulated Lead Acid Batteries As Per IS 15549 (1020 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI Marked	Yes, No
	Battery Voltage	2 Volt

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Battery Capacity (in Ah) at 10 H Rate	400 Ah
	Material of Container	Polypropylene Co-polymer (PPCP)
CONSTRUCTIONAL	Number of cells per battery	1 Cell for 2 Volt Battery
	Method of connections between cells	Bolted
	Warranty (in Years)	3 Years

Additional Specification Parameters - Stationary Value Regulated Lead Acid Batteries As Per IS 15549 (1020 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Supply, Installation, Testing and replacement of Sealed maintenance free 2V, 440Ah, Valve regulated Lead Acid (VRLA) Batteries bank (of not less than 204 nos. battery in each bank)	SMF 2V,440Ah VRLA Battery for 1x300kVA UPS System to provide minimum 30 minute of power backup to each 300kVA UPS along with heavy duty iron racks & Links i/c dismantling of old bank, from the existing UPS System, along with buy back & disposal of old Batteries bank with scrap racks removed from the existing 300kVA UPS etc. & perform testing as per guideline of OEM and tender condition etc. complete as per site requirement and as per direction of Engineer in charge.
Battery Capacity (in Ah)	440 Ah or higher instead of 400 Ah as mentioned above

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Prashant Kumar Ravi	492001,AIIMS Raipur Tatibandh	1020	180

Buyback Detail

Item Name	2 Volt, 440 Ah
Item Description	2 Volt, 440 Ah old batteries bank of 1020 no. of cells with scrap racks removed from the existing 300 KVA UPS etc.

Serial No.	00000
Model	UPST 440
Brand	EXIDE
Year of Manufacturing	2012
Purchase On	2012-11-01
Age	
Size	1
Rating	
Quantity	1020
Unit	Set
Remark	5 SET OF BANK EACH SET HAVE 204 NO. OF CELLS
Uploaded Image	View Uploaded Image
<p>Disclaimer/अस्वीकरण</p> <p>The vendor will be responsible for the un-installation of Buyback items.</p>	

Stationary Value Regulated Lead Acid Batteries As Per IS 15549 (612 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

* [As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	ISI Marked	No
	Battery Voltage	2 Volt
	Battery Capacity (in Ah) at 10 H Rate	150 Ah
	Material of Container	Polypropylene Co-polymenr (PPCP)
CONSTRUCTIONAL	Number of cells per battery	1 Cell for 2 Volt Battery
	Method of connections between cells	Bolted
	Warranty (in Years)	2 Years

Additional Specification Parameters - Stationary Value Regulated Lead Acid Batteries As Per IS 15549 (612 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Battery Capacity (in Ah)	165 Ah or higher instead of 150 Ah as mentioned above
Warranty	Minimum Warranty should be 3 years instead of 2 years as mentioned above
Supply, Installation, Testing and replacement of Sealed maintenance free 2V, 165Ah or higher, Valve regulated Lead Acid (VRLA) Batteries bank (of not less than 204 nos. battery in each bank	SMF 2V, 165Ah or higher VRLA Battery for 1x100kVA UPS System to provide minimum 30 minute of power backup to each 100kVA UPS along with heavy duty iron racks & Links i/c dismantling of old bank, from the existing UPS System, along with buy back & disposal of old Batteries bank with scrap racks removed from the existing 100kVA UPS etc. & perform testing as per guideline of OEM and tender condition etc. complete as per site requirement and as per direction of Engineer in charge.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र.सं.	Consignee Reporting/Officer/परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Prashant Kumar Ravi	492001,AIIMS Raipur Tatibandh	612	180

Buyback Detail

Item Name	2 Volt, 165 Ah
Item Description	2 Volt, 165 Ah old Batteries bank of 204 no. of cells with scrap racks removed from the existing 100 kVA UPS etc.
Serial No.	00000
Model	UPST 165
Brand	EXIDE
Year of Manufacturing	2012
Purchase On	2012-11-01
Age	
Size	1
Rating	
Quantity	612

Unit	3 set
Remark	3 SET OF BANKS, EACH SET HAVE 204 NO. OF CELLS
Uploaded Image	View Uploaded Image
Disclaimer/अस्वीकरण	
The vendor will be responsible for the un-installation of Buyback items.	

Buyer added Bid Specific Additional Scope of Work

S.No.क्र.सं.	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
1	Scope of Work for Bidders View	Stationary Value regulated Lead Acid Batteries As Per IS 15549(1020), Stationary Value Regulated Lead Acid Batteries As Per IS 15549 (612)	Stationary Value Regulated Lead Acid Batteries As Per IS 15549(1020)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Special terms and conditions-Version:1 effective from 04-05-2020 for category Stationary Value Regulated Lead Acid Batteries as per IS 15549

1. Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

Buyer Added Bid Specific Terms and Conditions/क्रिता द्वारा

जोड़ी गई बिड की विशेष शर्तें

1. If the agency is registered under MSME or NSIC, then EMD exemption certificate needs to be enclosed.
2. **Generic**

For hazardous chemical/item, all precautionary measure as per regulation from the point of transportation/ handling/ storage/ safety/ health/ environment to be undertaken/ specified before dispatch. During dispatch, proper symbol for the hazard/ MSDS/ Batch No./ date of manufacturing/ Gross Weight/ Net Weight/ shelf Life etc are to be written/ printed/ pasted on the body of the packing.

3. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

4. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

5. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. Preferred Make: - Exide/ HBL/ Amaron or Substantially Equivalent.
2. Bid specific OEM Authorization Certificate must be uploaded i.e. GeM Bid No. should be mentioned in OEM authorization Certificate.
3. The Bidder must submit technical specification compliance sheet and detailed product specification catalogue for the quoted product.
4. The bidder shall visit the site before bidding.

6. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

7. **Service & Support**

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

8. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

9. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

AIIMS Raipur
payable at
Raipur

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

10. **Warranty**

Warranty period of the supplied products shall be 3 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of

Service Centres near consignee destinations are to be uploaded along with the bid.

11. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

12. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 50 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 50% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids /

Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---